

4-23-2015

260922 - Contactors

Sandra Hickey
sandra.hickey@unh.edu

Follow this and additional works at: http://scholars.unh.edu/pdch_5_26

Recommended Citation

Hickey, Sandra, "260922 - Contactors" (2015). *Division 26 – Electrical*. 11.
http://scholars.unh.edu/pdch_5_26/11

This Article is brought to you for free and open access by the Chapter 5 – Technical Construction and Renovation Standards at University of New Hampshire Scholars' Repository. It has been accepted for inclusion in Division 26 – Electrical by an authorized administrator of University of New Hampshire Scholars' Repository. For more information, please contact nicole.hentz@unh.edu.

260922 - Contactors

SECTION 26 0922 - CONTACTORS

PART 1 - GENERAL

1.1 SUMMARY

- A. See Chapter 5, Division 01, Section 017700.1.1.B.1.i Closeout Procedures - Project Record Documents for equipment list requirements for all equipment provided in this section.
- B. Magnetic contactor for remote control of area lighting shall be mechanically held with coil clearing contacts of amperage rating required. Contactor shall be incorporated in panel by panel-board manufacturer. Contactors shall be controlled with momentary contact switches.
 - 1. Generally accepted equipment. Provide submittal for acceptance.

PART 2 - PRODUCTS

- 2.1 All magnetic contactors/starters datasheets shall be submitted to UNH Facilities for approval:
 - A. Magnetic contactors lighting and heating:
 - 1. ASCO - Bulletin 920.
 - 2. ITE - Bulletin 920 – Siemens.
 - 3. General Electric.
 - 4. ABB/Westinghouse/Cutler Hammer.
 - 5. Furnas.
 - 6. Square D.
 - B. Magnetic motor starters:
 - 1. General Electric.
 - 2. ABB/Westinghouse/Cutler Hammer.
 - 3. ITE – Siemens.
 - 4. Furnas.
 - 5. Square D.

END OF SECTION 26 0922