

University of New Hampshire

## University of New Hampshire Scholars' Repository

---

Division 22 – Plumbing

Chapter 5 – Technical Construction and  
Renovation Standards

---

4-23-2015

### 220000 - General Plumbing Requirements

Stephanie Weatherbee

University of New Hampshire, Durham, [s.weatherbee@unh.edu](mailto:s.weatherbee@unh.edu)

Follow this and additional works at: [https://scholars.unh.edu/pdch\\_5\\_22](https://scholars.unh.edu/pdch_5_22)

---

#### Recommended Citation

Weatherbee, Stephanie, "220000 - General Plumbing Requirements" (2015). *Division 22 – Plumbing*. 1.  
[https://scholars.unh.edu/pdch\\_5\\_22/1](https://scholars.unh.edu/pdch_5_22/1)

This Article is brought to you for free and open access by the Chapter 5 – Technical Construction and Renovation Standards at University of New Hampshire Scholars' Repository. It has been accepted for inclusion in Division 22 – Plumbing by an authorized administrator of University of New Hampshire Scholars' Repository. For more information, please contact [Scholarly.Communication@unh.edu](mailto:Scholarly.Communication@unh.edu).



**SECTION 22 0000 – GENERAL PLUMBING REQUIREMENTS**

1.1 SUMMARY

- A. Building Services Identification Labeling – The University has adopted a comprehensive label identification for the distribution systems for all plumbing, fire protection, air, mechanical piping, electrical, fire alarm, controls, telecommunications, audio/visual, and security. The specific label colors, text, and directional flows for each component part are described in a single comprehensive table that is Chapter 5, Appendix A, Building Services Identification labeling. This labeling system must be part of any construction project, even those that are limited to a portion of a building or a single utility system.
- B. See Chapter 5, Division 01, Section 017700.1.1.B.1.i Closeout Procedures - Project Record Documents for equipment list requirements for all equipment provided in this section.
- C. The height of ceiling grids must be carefully coordinated with all MEP, FP, and Telecom systems in the plenum above the ceiling. Maintain a minimum clearance of 3” to allow UNH staff to move all tiles after the full installation is completed. Avoid obstructions with equipment and distribution piping so that tiles can be easily pushed up and slid sideways. All subcontractors working in the ceiling plenum must understand this requirement.
- D.

END OF SECTION 22 0000