

University of New Hampshire

## University of New Hampshire Scholars' Repository

---

Division 08 – Openings

Chapter 5 – Technical Construction and  
Renovation Standards

---

1-23-2015

### 082250 - Fiberglass Reinforced Polymer (FRP) Doors

Stephanie Weatherbee  
s.weatherbee@unh.edu

Follow this and additional works at: [https://scholars.unh.edu/pdch\\_5\\_08](https://scholars.unh.edu/pdch_5_08)

---

#### Recommended Citation

Weatherbee, Stephanie, "082250 - Fiberglass Reinforced Polymer (FRP) Doors" (2015). *Division 08 – Openings*. 3.  
[https://scholars.unh.edu/pdch\\_5\\_08/3](https://scholars.unh.edu/pdch_5_08/3)

This Article is brought to you for free and open access by the Chapter 5 – Technical Construction and Renovation Standards at University of New Hampshire Scholars' Repository. It has been accepted for inclusion in Division 08 – Openings by an authorized administrator of University of New Hampshire Scholars' Repository. For more information, please contact [Scholarly.Communication@unh.edu](mailto:Scholarly.Communication@unh.edu).

## **SECTION 08 2250 – FIBERGLASS REINFORCED POLYMER (FRP) DOORS**

### 1.1 SUMMARY

- A. The University prefers to use regional materials within a 500 mile radius of the campus.
- B. Section includes the following:
  - 1. Exterior fiberglass reinforced polymer (FRP) doors.
  - 2. Aluminum frames for FRP doors.

### 1.2 QUALITY ASSURANCE

- A. Fire Performance Characteristics: Provide Class 'A' fiber reinforced polymer faces with the following surface burning characteristics as determined by testing identical products per ASTM E 84 by UL or other testing and inspecting organizations acceptable to authorities having jurisdiction.
  - 1. Flame Spread: 25 or less.
  - 2. Smoke Developed: 450 or less.

### 1.3 MANUFACTURERS

- A. Manufacturers:
  - 1. Special-Lite, Inc.
  - 2. Tubelite, Inc.
  - 3. Commercial Door Systems.

### 1.4 MATERIALS

- A. Aluminum Members: ASTM B 221 for extrusions and ASTM B 209 for sheet and plate.
- B. Steel Reinforcement: ASTM A 36 for structural shapes, plates, and bars; ASTM A 611 for cold-rolled sheet and strip; or ASTM A 570 for hot-rolled sheet and strip.
- C. Fiberglass Reinforced Polymer Face Material: 0.120 inch min. thickness, with color integral through full thickness of face sheet. Provide pebble-like embossed finish for flush doors.
- D. Core Material: Urethane foam.
- E. Fasteners: Aluminum or stainless steel.

1.5 DOORS

- A. General: Provide standard flush style embossed panel doors, constructed of aluminum stiles and rails joined with steel tie rods, with polymer face sheets and foamed-in-place urethane inner core.
  - 1. Manufacturers:
    - a. Special-Lite, Inc.
    - b. Tubelite Commercial Grade

1.6 FRAMES

- A. Frames: Provide tubular extruded aluminum frame members, 2 by 4-1/2 inches or 2 by 6 inches; with minimum 1/8 inch thick walls and closed back. Fabricate with mechanical joints using heavy inserted reinforcing plates and concealed tie-rods or j-bolts. Supply with 1/2 by 1-1/4 inch door stop, with heavy-duty weathering pile included.
- B. Products:
  - 1. Model SL-245 FG (2 by 4-1/2 inch frame); Special-Lite.
  - 2. Model SL-260 FG (2 by 6 inch frame); Special Lite.

END OF SECTION 08 2250