

4-23-2015

334600 - Subdrainage

Sandra Hickey
sandra.hickey@unh.edu

Follow this and additional works at: https://scholars.unh.edu/pdch_5_33

Recommended Citation

Hickey, Sandra, "334600 - Subdrainage" (2015). *Division 33 – Utilities*. 3.
https://scholars.unh.edu/pdch_5_33/3

This Article is brought to you for free and open access by the Chapter 5 – Technical Construction and Renovation Standards at University of New Hampshire Scholars' Repository. It has been accepted for inclusion in Division 33 – Utilities by an authorized administrator of University of New Hampshire Scholars' Repository. For more information, please contact nicole.hentz@unh.edu.

SECTION 33 4600 - SUBDRAINAGE

1.1 SUMMARY

A. Section Includes:

1. Perforated-wall pipe and fittings.
2. Geotextile filter fabrics.

B. See Chapter 5, Division 01, Section 017700.1.1.B.1.i Closeout Procedures - Project Record Documents for equipment list requirements for all equipment provided in this section.

1.2 PERFORATED-WALL PIPES AND FITTINGS

A. Perforated PE Pipe and Fittings: ASTM F 405 or AASHTO M 252, Type CP; corrugated, for coupled joints.

1.3 WATERPROOFING FELTS

A. Material: Comply with ASTM D 226, Type I, asphalt or ASTM D 227, coal-tar-saturated organic felt.

1.4 GEOTEXTILE FILTER FABRICS

A. Description: Fabric of PP or polyester fibers or combination of both, with flow rate range from 110 to 330 gpm/sq. ft. (4480 to 13 440 L/min. per sq. m) when tested according to ASTM D 4491.

B. Structure Type: Nonwoven, needle-punched continuous filament.

1. Survivability: AASHTO M 288 Class 2.
2. Styles: Flat and sock.

END OF SECTION 33 4600