

University of New Hampshire

University of New Hampshire Scholars' Repository

Division 07 – Thermal and Moisture Protection

Chapter 5 – Technical Construction and
Renovation Standards

1-25-2013

074213 - Metal Wall Panels

Stephanie Weatherbee
s.weatherbee@unh.edu

Follow this and additional works at: https://scholars.unh.edu/pdch_5_07

Recommended Citation

Weatherbee, Stephanie, "074213 - Metal Wall Panels" (2013). *Division 07 – Thermal and Moisture Protection*. 10.

https://scholars.unh.edu/pdch_5_07/10

This Article is brought to you for free and open access by the Chapter 5 – Technical Construction and Renovation Standards at University of New Hampshire Scholars' Repository. It has been accepted for inclusion in Division 07 – Thermal and Moisture Protection by an authorized administrator of University of New Hampshire Scholars' Repository. For more information, please contact Scholarly.Communication@unh.edu.

SECTION 07 4213 - METAL WALL PANELS

1.1 SUMMARY

- A. The University prefers to use regional materials within a 500 mile radius of the campus.
- B. Section Includes:
 - 1. Formed metal copper wall panels at exterior walls.
 - 2. Fabricated copper louvers to match metal wall panels.

1.2 SUBMITTALS

- A. LEED Submittals:
 - 1. Product Data for Credit MR 4.1 and Credit MR 4.2: Indicate percentages by weight of postconsumer and preconsumer recycled content for products having recycled content.
 - a. Include statement indicating costs for each product having recycled content.
 - 2. Product Data for Credit MR 5.1 and Credit MR 5.2: For regional materials indicating location and distance from Project of material manufacturer and point of extraction, harvest, or recovery for each raw material.
 - a. Include statement indicating cost for each regional material and the fraction by weight that is considered regional.

1.3 QUALITY ASSURANCE

- A. Custom-Fabricated Sheet Metal Wall Fabricator/Installer Qualifications: Shop that employs skilled workers who custom-fabricate sheet metal work similar to that required for the project and whose products have a record of successful in-service performance with a minimum of three (3) projects similar in scope.
- B. Fire-Resistance Ratings: Where indicated, provide metal wall panels identical to those of assemblies tested for fire resistance per ASTM E 119 by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.

1.4 PANEL MATERIALS

- A. Copper Sheet: ASTM B 370; temper H00, cold-rolled, except where temper 060 is required for forming; not less than 20 oz./sq. ft.
 - 1. Manufacturer: Revere Copper.
 - 2. Finish: Natural Copper.

- B. Approved Fabricators/Installers: Provide shop-fabricated copper panels fabricated and installed by one of the following:
1. Crocker Architectural.
 2. Gilbert and Becker.
 3. Oak.

END OF SECTION 07 4213