

University of New Hampshire

## University of New Hampshire Scholars' Repository

---

Division 07 – Thermal and Moisture Protection

Chapter 5 – Technical Construction and  
Renovation Standards

---

1-25-2013

### 075419 - PVC Roofing

Stephanie Weatherbee  
s.weatherbee@unh.edu

Follow this and additional works at: [https://scholars.unh.edu/pdch\\_5\\_07](https://scholars.unh.edu/pdch_5_07)

---

#### Recommended Citation

Weatherbee, Stephanie, "075419 - PVC Roofing" (2013). *Division 07 – Thermal and Moisture Protection*.  
14.  
[https://scholars.unh.edu/pdch\\_5\\_07/14](https://scholars.unh.edu/pdch_5_07/14)

This Article is brought to you for free and open access by the Chapter 5 – Technical Construction and Renovation Standards at University of New Hampshire Scholars' Repository. It has been accepted for inclusion in Division 07 – Thermal and Moisture Protection by an authorized administrator of University of New Hampshire Scholars' Repository. For more information, please contact [Scholarly.Communication@unh.edu](mailto:Scholarly.Communication@unh.edu).

## SECTION 07 5419 - PVC ROOFING

### 1.1 SUMMARY

- A. Section Includes:
1. Adhered PVC membrane roofing system.
  2. Vapor retarder.
  3. Roof insulation.

### 1.2 DEFINITIONS

- A. Roofing Terminology: See ASTM D 1079 and glossary in NRCA's "The NRCA Roofing and Waterproofing Manual" for definition of terms related to roofing work in this Section.

### 1.3 PERFORMANCE REQUIREMENTS

- A. General Performance: Installed membrane roofing and base flashings shall withstand specified uplift pressures, thermally induced movement, and exposure to weather without failure due to defective manufacture, fabrication, installation, or other defects in construction. Membrane roofing and base flashings shall remain watertight.
- B. FM Approvals Listing: Provide membrane roofing, base flashings, and component materials that comply with requirements in FM Approvals 4450 and FM Approvals 4470 as part of a membrane roofing system, and that are listed in FM Approvals' "RoofNav" for Class 1 or noncombustible construction, as applicable. Identify materials with FM Approvals markings.
1. Fire/Windstorm Classification: Class 1A-90.
- C. Energy Performance: Provide roofing system with initial Solar Reflectance Index not less than 78 when calculated according to ASTM E 1980, based on testing identical products by a qualified testing agency.

### 1.4 SUBMITTALS

- A. LEED Submittals:
1. Product Data for Credit SS 7.2: For roof materials, indicating that roof materials comply with Solar Reflectance Index requirement.
  2. Product Data for Credit EQ 4.1: For adhesives and sealants, including printed statement of VOC content.

### 1.5 QUALITY ASSURANCE

- A. **Manufacturer Qualifications:** A qualified manufacturer that is UL listed for membrane roofing system identical to that used for this Project.
- B. **Exterior Fire-Test Exposure:** ASTM E 108, Class A; for application and roof slopes indicated, as determined by testing identical membrane roofing materials by a qualified testing agency. Materials shall be identified with appropriate markings of applicable testing agency.
- C. **Fire-Resistance Ratings:** Where indicated, provide fire-resistance-rated roof assemblies identical to those of assemblies tested for fire resistance per ASTM E 119 by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.

### 1.6 PVC MEMBRANE ROOFING

- A. **PVC Sheet:** ASTM D 4434, Type II, Grade I, glass fiber reinforced, felt backed.
  - 1. **Product:** Sarnafil Inc; Sarnafil G410.
  - 2. **Thickness:** 48 mils (1.2 mm), minimum or 60 mils (1.5 mm), nominal.
  - 3. **Exposed Face Color:** Gray.
- B. **PVC Sheet:** ASTM D 4434, Type III, fabric reinforced and fabric backed.
  - 1. **Manufacturers:**
    - a. Carlisle SynTec, Incorporated.
    - b. GAF Materials Corporation.
    - c. GenFlex Roofing Systems.
    - d. Johns Manville.
    - e. Sarnafil Inc.
    - f. Stevens Roofing Systems.
    - g. Versico Incorporated.
  - 2. **Thickness:** 45 mils (1.1 mm), minimum or 60 mils (1.5 mm), nominal.
  - 3. **Exposed Face Color:** White or Gray.

### 1.7 AUXILIARY MEMBRANE ROOFING MATERIALS

- A. **General:** Auxiliary membrane roofing materials recommended by roofing system manufacturer for intended use, and compatible with membrane roofing.
  - 1. Liquid-type auxiliary materials shall comply with VOC limits of authorities having jurisdiction.
  - 2. Adhesives and sealants that are not on the exterior side of weather barrier shall comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA Method 24):

- a. Plastic Foam Adhesives: 50 g/L.
- b. Gypsum Board and Panel Adhesives: 50 g/L.
- c. Multipurpose Construction Adhesives: 70 g/L.
- d. Fiberglass Adhesives: 80 g/L.
- e. Contact Adhesive: 80 g/L.
- f. Other Adhesives: 250 g/L.
- g. PVC Welding Compounds: 510 g/L.
- h. Adhesive Primer for Plastic: 650 g/L.
- i. Single-Ply Roof Membrane Sealants: 450 g/L.
- j. Nonmembrane Roof Sealants: 300 g/L.
- k. Sealant Primers for Nonporous Substrates: 250 g/L.
- l. Sealant Primers for Porous Substrates: 775 g/L.

#### 1.8 VAPOR RETARDER

- A. Polyethylene Film: ASTM D 4397, 6 mils (0.15 mm) thick, minimum, with maximum permeance rating of 0.13 perm (7.5 ng/Pa x s x sq. m).
  - 1. Tape: Pressure-sensitive tape of type recommended by vapor-retarder manufacturer for sealing joints and penetrations in vapor retarder.
  - 2. Adhesive: Manufacturer's standard lap adhesive, FM Approvals approved for vapor-retarder application.

#### 1.9 ROOF INSULATION

- A. Polyisocyanurate Board Insulation: ASTM C 1289, Type II, Class I, Grade 3, felt or glass-fiber mat facer on both major surfaces.
- B. Provide preformed saddles, crickets, tapered edge strips, and other insulation shapes where indicated for sloping to drain. Fabricate to slopes indicated.

#### 1.10 WALKWAYS

- A. Flexible Walkways: Factory-formed, nonporous, heavy-duty, slip-resisting, surface-textured walkway pads or rolls, approximately 3/16 inch (5 mm) thick, and acceptable to membrane roofing system manufacturer.

#### 1.11 INSULATION INSTALLATION

- A. Mechanically Fastened and Adhered Insulation: Install each layer of insulation and secure first layer of insulation to deck using mechanical fasteners specifically designed and sized for fastening specified board-type roof insulation to deck type.

1.12 ADHERED MEMBRANE ROOFING INSTALLATION

- A. Adhere membrane roofing over area to receive roofing and install according to membrane roofing system manufacturer's written instructions.

- 1. Install sheet according to ASTM D 5036.

END OF SECTION 07 5419