

1-25-2013

064023 - Interior Architectural Woodwork

Sandra Hickey
sandra.hickey@unh.edu

Follow this and additional works at: http://scholars.unh.edu/pdch_5_06

Recommended Citation

Hickey, Sandra, "064023 - Interior Architectural Woodwork" (2013). *Division 06 – Wood, Plastics and Composites*. 3.
http://scholars.unh.edu/pdch_5_06/3

This Article is brought to you for free and open access by the Chapter 5 – Technical Construction and Renovation Standards at University of New Hampshire Scholars' Repository. It has been accepted for inclusion in Division 06 – Wood, Plastics and Composites by an authorized administrator of University of New Hampshire Scholars' Repository. For more information, please contact nicole.hentz@unh.edu.

064023 - Interior Architectural Woodwork

SECTION 06 4023 - INTERIOR ARCHITECTURAL WOODWORK

1.1 SUMMARY

A. This Section includes the following:

1. Interior standing and running trim.
2. Interior frames and jambs.
3. Stairwork and rails.
4. Flush wood paneling and wainscots.
5. Interior ornamental work.
6. Wood cabinets.
7. Plastic-laminate cabinets.
8. Plastic-laminate countertops.
9. Solid-surfacing-material countertops.
10. Laminated-plastic laboratory tops.
11. Closet and utility shelving.
12. Shop finishing of interior woodwork.

1.2 SUBMITTALS

A. LEED Submittals:

1. Product Data for Credit EQ 4.1: For installation adhesives, including printed statement of VOC content.
2. Product Data for Credit EQ 4.4:
 - a. For each composite-wood product used, documentation indicating that the bonding agent contains no urea formaldehyde.
 - b. For each adhesive used, documentation indicating that the adhesive contains no urea formaldehyde.
3. Product Data for Credit(s) MR 4.1 and MR 4.2: For products having recycled content, documentation indicating percentages by weight of postconsumer and preconsumer recycled content.
 - a. Include statement indicating costs for each product having recycled content.
4. Certificates for Credit MR 7: Chain-of-custody certificates certifying that products specified to be made from certified wood comply with forest certification requirements. Include evidence that mill is certified for chain of custody by an FSC-accredited certification body.
 - a. Include statement indicating costs for each certified wood product.

5. The University encourages the use of regional materials located within a 500 mile radius of the campus. Provide appropriate documentation verifying.

1.3 QUALITY ASSURANCE

- A. Quality Standard: Unless otherwise indicated, comply with AWI's "Architectural Woodwork Quality Standards" for grades of interior architectural woodwork indicated for construction, finishes, installation, and other requirements.
- B. Fire-Test-Response Characteristics: Where fire-retardant materials or products are indicated, provide materials and products with specified fire-test-response characteristics as determined by testing identical products per test method indicated by UL, ITS, or another testing and inspecting agency acceptable to authorities having jurisdiction. Identify with appropriate markings of applicable testing and inspecting agency in the form of separable paper label or, where required by authorities having jurisdiction, imprint on surfaces of materials that will be concealed from view after installation.
- C. Forest Certification: Provide interior architectural woodwork produced from wood obtained from forests certified by an FSC-accredited certification body to comply with FSC STD-01-001, "FSC Principles and Criteria for Forest Stewardship."
- D. Regional Certification. Provide documentation of indicating regional certification.

1.4 MATERIALS

- A. General: Provide materials that comply with requirements of AWI's quality standard for each type of woodwork and quality grade specified, unless otherwise indicated.
- B. Wood Species and Cut for Transparent Finish: White or Red Oak, Maple, Cherry, rift sawn or cut.
- C. Wood Species for Opaque Finish: Any closed-grain hardwood.
- D. Wood Products: Comply with the following:
 1. Recycled Content of Medium-Density Fiberboard and Particleboard: Provide products with an average recycled content so postconsumer recycled content plus one-half of preconsumer recycled content is not less than 25 percent.
 2. Hardboard: AHA A135.4.
 3. Medium-Density Fiberboard: ANSI A208.2, Grade MD, made with binder containing no urea formaldehyde.
 4. Particleboard: ANSI A208.1, Grade M-2-Exterior Glue.
 5. Particleboard: Straw-based particleboard complying with requirements in ANSI A208.1, Grade M-2, except for density.
 6. Softwood Plywood: DOC PS 1, Medium Density Overlay.
 7. Veneer-Faced Panel Products (Hardwood Plywood): HPVA HP-1, made with adhesive containing no urea formaldehyde.

- E. Thermoset Decorative Panels: Particleboard or medium-density fiberboard finished with thermally fused, melamine-impregnated decorative paper complying with LMA SAT-1.
 - 1. Provide PVC or polyester edge banding complying with LMA EDG-1 on components with exposed or semi-exposed edges.
- F. High-Pressure Decorative Laminate: NEMA LD 3, grades as indicated or, if not indicated, as required by woodwork quality standard.
 - 1. Available Manufacturers:
 - a. Abet Laminati, Inc.
 - b. Arborite; Division of ITW Canada, Inc.
 - c. Formica Corporation.
 - d. Lamin-Art, Inc.
 - e. Nevamar Company, LLC; Decorative Products Div.
 - f. Panolam Industries International Incorporated.
 - g. Westinghouse Electric Corp.; Specialty Products Div.
 - h. Wilsonart International; Div. of Premark International, Inc.
- G. Chemical-Resistant, High-Pressure Decorative Laminate: NEMA LD 3, Grade HGP, and as follows:
 - 1. Laminate has the following ratings when tested with indicated reagents according to NEMA LD 3, Test Procedure 3.9.5:
 - a. Nitric Acid (30 Percent): Moderate effect.
 - b. Sulfuric Acid (77 Percent): Moderate effect.
 - c. Hydrochloric Acid (37 Percent): Moderate effect.
 - d. Phosphoric Acid (75 Percent): No effect.
 - e. Acetic Acid (98 Percent): No effect.
 - f. Formaldehyde: No effect.
 - g. Ethyl Acetate: No effect.
 - h. Ethyl Ether: No effect.
 - i. Phenol (85 Percent): Moderate effect.
 - j. Benzene: No effect.
 - k. Xylene: No effect.
 - l. Butyl Alcohol: No effect.
 - m. Furfural: No effect.
 - n. Methyl Ethyl Ketone: No effect.
 - o. Sodium Hydroxide (25 Percent): No effect.
 - p. Sodium Sulfide (15 Percent): No effect.
 - q. Ammonium Hydroxide (28 Percent): No effect.
 - r. Zinc Chloride: No effect.
 - s. Gentian Violet: No effect.
 - t. Methyl Red: No effect.
- H. Solid-Surfacing Material: Homogeneous solid sheets of filled plastic resin complying with ISSFA-2.

1. Available Manufacturers:
 - a. ABA Industries.
 - b. Avonite, Inc.
 - c. E. I. du Pont de Nemours and Company.
 - d. Formica Corporation.
 - e. LG Chemical, Ltd.
 - f. Meganite Inc.; a division of the Pyrochem Group.
 - g. Nevamar Company, LLC; Decorative Products Div.
 - h. Samsung; Cheil Industries Inc.
 - i. Swan Corporation (The).
 - j. Transolid, Inc.
 - k. Wilsonart International; Div. of Premark International, Inc.
2. Type: Standard type or Veneer type made from material complying with requirements for Standard type, as indicated, unless Special Purpose type is indicated.

1.5 FIRE-RETARDANT-TREATED MATERIALS

- A. General: Where fire-retardant-treated materials are indicated, use materials complying with requirements in this Section, that are acceptable to authorities having jurisdiction, and with fire-test-response characteristics specified.

1.6 CABINET HARDWARE AND ACCESSORIES

- A. Butt Hinges: 2-3/4-inch (70-mm), 5-knuckle steel hinges made from 0.095-inch- (2.4-mm-) thick metal, and as follows:
 1. Semi-concealed Hinges for Flush Doors: BHMA A156.9, B01361.
 2. Semi-concealed Hinges for Overlay Doors: BHMA A156.9, B01521.
- B. Frameless Concealed Hinges (European Type): BHMA A156.9, B01602, 100 degrees of opening, self-closing.
- C. Back-Mounted Pulls: BHMA A156.9, B02011.
- D. Wire Pulls: Back mounted, stainless steel, 4 inches (100 mm) long, 5/16 inch (8 mm) in diameter.
- E. Drawer Slides: BHMA A156.9, B05091.
- F. Grommets for Cable Passage through Countertops: 2-inch (51-mm) OD, molded-plastic grommets and matching plastic caps with slot for wire passage.
- G. Exposed Hardware Finishes: For exposed hardware, provide finish that complies with BHMA A156.18 for BHMA finish number indicated.
 1. Satin Stainless Steel: BHMA 630.Or Owner specified finish for a specific project.

1.7 MISCELLANEOUS MATERIALS

- A. Adhesives, General: Do not use adhesives that contain urea formaldehyde.
- B. VOC Limits for Installation Adhesives and Glues: Use installation adhesives that comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA Method 24):
 - 1. Wood Glues: 30 g/L.
 - 2. Contact Adhesive: 250 g/L.
- C. Adhesive for Bonding Plastic Laminate: Resorcinol.

1.8 FABRICATION, GENERAL

- A. Interior Woodwork Grade: Unless otherwise indicated, provide Premium-grade interior woodwork complying with referenced quality standard.

1.9 SHOP FINISHING

- A. Grade: Provide finishes of same grades as items to be finished.
- B. General: Shop finish transparent-finished interior architectural woodwork at fabrication shop as specified in this Section. Refer to Chapter 5, Division 09, Section 099100 for finishing opaque-finished architectural woodwork.
- C. Shop Priming: Shop apply the prime coat including backpriming, if any, for items specified to be field finished. Refer to Chapter 5, Division 09, Section 099100 for material and application requirements.

END OF SECTION 06 4023