

4-23-2015

## 262817 - Enclosed Transfer Switches

Sandra Hickey  
sandra.hickey@unh.edu

Follow this and additional works at: [http://scholars.unh.edu/pdch\\_5\\_26](http://scholars.unh.edu/pdch_5_26)

---

### Recommended Citation

Hickey, Sandra, "262817 - Enclosed Transfer Switches" (2015). *Division 26 – Electrical*. 17.  
[http://scholars.unh.edu/pdch\\_5\\_26/17](http://scholars.unh.edu/pdch_5_26/17)

This Article is brought to you for free and open access by the Chapter 5 – Technical Construction and Renovation Standards at University of New Hampshire Scholars' Repository. It has been accepted for inclusion in Division 26 – Electrical by an authorized administrator of University of New Hampshire Scholars' Repository. For more information, please contact [nicole.hentz@unh.edu](mailto:nicole.hentz@unh.edu).

---

## 262817 - Enclosed Transfer Switches

## **SECTION 26 2817 - ENCLOSED TRANSFER SWITCH**

### **PART 1 GENERAL**

1.1 See Chapter 5, Division 01, Section 017700.1.1.B.1.i Closeout Procedures - Project Record Documents for equipment list requirements for all equipment provided in this section.

#### **1.2 POWER**

- A. The design team will determine whether the facility will have emergency power transfer (life safety items only) or whether the facility will have stand-by power transfer (other than life safety) or both.

#### **1.3 LIGHTING**

- A. The design team will determine whether the facility will have emergency lighting that will be switched.

#### **1.4 GFCI MAINS**

- A. All buildings that are to be served by 3-phase GFCI Main Breakers, and equipped with generators for Emergency and Standby use shall have 4-Pole Overlapping Neutral (make before break type) Transfer Switches.

### **PART 2 - PRODUCTS**

#### **2.1 GENERAL ACCEPTABLE EQUIPMENT**

- A. Provide submittal for approval.
  - 1. All enclosed transfer switches datasheets shall be submitted to the client for approval.
- B. Emergency/Stand-by Power Transfer Switches: Generally acceptable manufacturers.
  - 1. Onan.
  - 2. Caterpillar.
  - 3. Russelectric.
  - 4. Generac.
  - 5. ASCO/Emerson.
  - 6. KOHLER.
- C. Emergency Lighting Transfer Switches: Generally acceptable manufacturers.

1. Entertainment network:
  - a. RHG-120.
  - b. RHG-277.
  - c. NINE 24, Inc.
  - d. BLTC-R-120.
  - e. BLTC-R-277.
  - f. BLTC-I-120.
  - g. BLTC-I-277.

END OF SECTION 26 2817